



## Minutes

### Labeling Subcommittee

Wednesday, July 22, 2009

*Under Ratings Committee Block: 2:00 p.m. – 5:00 p.m.*

Chair: *John McFee, Window & Door Manufacturing Association (WDMA)*

Vice Chair: *TBD*

---

1. John McFee called the meeting to order at 2:53 PM- antitrust reminder given and reviewed voting
2. Sherri Wendt (NFRC Staff) was appointed recording secretary.
3. The agenda was reviewed and approved as presented.
4. Minutes from March 2009 meeting in Tucson, AZ were approved as presented.
5. Reports
  - a. CMA Label TG – C. Curcija reported that CMA is ready to go and that the TG will be suspended until there are more items.
  - b. Attachment Label TG – T. Morrissey reported that technical documents need to be in place prior to moving forward for the 100 and 200 to progress. Discuss differences between permanent and temporary labels – recently clarified language that it is in the PCP. No new action items.
6. New Business
  - a. Discuss requirements for metric labeling – J. Baker
    - i. PCP Figure B-11 the use of metric units: using 2 decimals is not defined in the text of the PCP. Request from natural recourses of Canada to bring the places to two reading decimals “0.00” it will imply a greater level of accuracy to allow for the same number of decimals for the Canadian label. Requesting PCP language to be changed. This is an issue because the calculation by the IA needs to have a level of equivalency from IP to SI unit.
    - ii. M. Thoman stated the Section 4.6.4 has the requirement to round to the nearest “0.05 W/m<sup>2</sup>K”. Recommendations: to change NFRC 100 section to read 0.01 from 0.05.
    - iii. Metric ratings and labeling issues as a new workgroup that J. Baker will chair. Scope: Allow metric numbers in the CPD for the ability to cross check the data during inspections.
  - b. Print labeling info on outside of the box – D. DeBlock
    - i. SC agreed that ODL is within the requirements per Appendix B to print the label at their recommended sizes
    - ii. Direct the PCP task group to look at the language for PCP Appendix B.2 to include “width” and “height” requirements or allow a larger NFRC label.
7. The meeting was adjourned at 3:24 PM