

Technical Interpretation Policy Committee

June 21, 2010

3:30 pm – 5:00 pm

Chair: Tom Culp, Birch Point Consulting, LLC

Vice Chair: Randy Van Voorst, NCTL-NW/Quality Testing

Staff Liaison: Dennis Anderson

Minutes

- Roll Call at 3:33 PM ET:

COMPANY	NAME	PRESENT
Birch Point Consulting, LLC	Tom Culp (Chair)	Y
Quality Testing, Inc.	Randy Van Voorst (Vice-Chair)	N
Architectural Testing, Inc.	Mike Thoman	Y
WESTLab	Jeff Baker	Y
AMSCO Windows	Joe Jonely	Y
Jeld Wen	Steve Strawn	Y
Carli	Charlie Curcija	Y
Associated Labs, Inc.	Brad Schultz	N

- Invited guests in attendance was: Greg McKenna of Kawneer
- Agenda reviewed and approved
- Previous conference call minutes
 - **Motion:** S. Strawn / J. Baker motioned to approve the minutes from the May 12, 2010 conference call. Passed by unanimous voice vote.
- Unfinished Business:
 - Review of TIR-2010-04. Tabled till next call to allow more time for TIPC to review.
 - Review of TIR-2010-05. Proposed interpretation was revised by TIPC to include all vents and not just concealed vents and that they shall be rated as stand-alone products.
Motion: M. Thoman / S. Strawn motioned to approve TIR-2010-05, as revised. Motion passed by vote of 6-0.
Note: This approved TIR will be numbered as TI-2010-04 and will be brought forward to the CMA Steering Committee for grandfathering in concealed vent products already simulated and tested.
- Joe Jonely had to depart call at 4:10 ET but quorum still maintained.
- Review of TIR-2010-06.
 - J. Baker thought this TIR was considered new language and not an interpretation. However, modeling procedures for simulation of products is the purview of TIPC and introducing language to clarify what a simulator needs to do should be considered.
 - The main concern with the modeling procedure for CMA single-glazing is the section 1.b of the interpretation. An alternative solution discussed was inserting glass to fill the void vacated between the glazing bead (up to the sightline) and the 6mm glazing that Therm automatically inserts.
 - It was suggested to advise the author of this TIR (L. Turner) to work with the CMAST developers on a work-around solution rather than manipulating the glazing bead or glass.

- Review of TIR-2010-07. Tabled till next call

- New Business:
 - None
- Adjourned at 4:34 PM ET.