

NFRC 100 Garage-Rolling Door Ballot [\(click here to access the original proposed ballot\)](#)



NFRC Ballot Comments through November 2, 2009 Technical Committee – U-Factor Subcommittee

Legend:

AC :Approve with Comment

NEG: Negative response with Comments

Company Name, Rep Initials	AC/NEG	Section and/or Page #	Comment/Alternate Language
Newpro Manufacturing, DC	NEG		<i>No comments submitted</i>
Carli, CC	APC		It is not clear what "edge of panel" area is included in these calculations. List of individual (2-D) U-factors includes "edge of glazing" only, as if there is no "edge of panel" areas. Also, edge dimensions that are specified as greater of 2.5 in. and 1 in. is not clear and should be clarified. Greater of 2.5 in. and 1 in. is always 2.5 in., so it is not clear what did authors meant here.
WESTLab, JB	APC		While I under that product size was not in this ballot, but the size needs to be revisited and should be changed to 8' wide by 7' height.