

NFRC 200 Garage Door Ballot [\(click here to access the original proposed ballot\)](#)



Legend:

AC :Approve with Comment

NEG: Negative response with Comments

**NFRC Ballot Comments through November 2, 2009
Technical Committee – Solar Heat Gain Subcommittee**

Company Name, Rep Initials	AC/ NEG	Section and/or Page #	Comment/Alternate Language
Carli, CC	APC		Same comments as for 100 Garage Door ballot with the following addition: Under 5.5.5.A.ii there is a mention of "edge of glazing SHGC" I have never heard of anything like that, so unless there is some special reason that I did not see in the document that needs to be combined with subsection "i" to say "entire glazing area SHGC"
WESTLab, JB	APC		While I under that product size was not in this ballot, but the size needs to be revisited and should be changed to 8' wide by 7' height.