

NFRC 700 Film Label Ballot ([click here to access the original proposed ballot](#) & [supporting spreadsheet](#))



NFRC Ballot Comments through November 2, 2009
Ratings Committee – Labeling Subcommittee

Legend:

AC: Approve with Comment

NEG: Negative response with Comments

Company Name, Rep Initials	AC/ NEG	Section and/or Page #	Comment/Alternate Language
Sunergy, W.dP.	NEG	Fig. B-4A	1) The label should show U-Factor, SHGC and VT for the Base Case Window "Without Film" in addition to "With Film."
Sunergy, W.dP.	NEG	Fig. B-4A	2) With regard to the glass options and values shown on the label and in the spreadsheet, use the default products specified in NFRC 100-A and by the Fenestration Attachment Subcommittee.
Cardinal, J.L.	NEG	General	Add commentary to label indicating that ratings should not be used for code compliance
Andersen Corp., S.J.	NEG	General	Why retain residential and non-residential classifications? Those classifications were eliminated some time ago in the existing window rating program. How will the consumer know whether the film is being applied to a residential or a commercial window, especially in retro-fit applications? There is no indicator on the window.
Alliance to Save Energy, N.P.	NEG	General	In my comments on the NFRC 100 and 200 ballots for applied films I propose a different set of reference windows: 1. single pane w/ metal frame; 2. single pane w/ non-metal frame; 3. double pane w/ metal frame; 4. double pane w/ non-metal frame. If these reference window classes were to be used, the label would have to be changed accordingly.
Hunter Douglas, M.C.	APC	General	references to " attachment products" in the NFRC 700 document should be consistent with other applied films language in order to differentiate Applied Films from other Fenestration Attachment products