

Air Leakage Task Group
Conference Call Agenda & Meeting Minutes
Thursday, May 8, 2010
2:00 p.m. – 3:30 p.m. EDT
Chair: Chris Nolt, ProVia Door

Meeting Minutes

- 1) Attendees – Brad Schultz, Chris Nolt, Dennis Anderson, Joe Hayden, Ken Brendan, Roger LeBrun, Scott Hanlon.
- 2) Reviewed ballot comments for the NFRC 400-2010 spring 2010 ballot.
 - a. Associated Laboratories is withdrawing their negatives. They did not realize the operating force table was being removed from NFRC 400 as the ballot formatting did not show the table crossed-out.
 - b. Associated Material's negative was considered persuasive by the task group.
 - i. The task group determined Section 4.E should be rewritten as "The leakage rate shall be measured and rounded to one decimal place in L/s·m² (i.e., #.#) in accordance with the Absolute Method outlined in ASTM E 29.
 - ii. Must add "ASTM E 29 Standard Practice for Using Significant Digits in Test Data to Determine Conformance with Specifications" to Section 6.
 - iii. Birch Point Consulting's negatives were considered editorial and persuasive. All the "NAFS" language within the ballot to be replaced with "AAMA/WDMA/CSA 101/I.S.2/A440".
- 3) Reviewed ballot comments for the NFRC 400-2010 TI spring 2010 ballot.
 - a. Associated Material's first comment sentence considered editorial and persuasive by task group. Last sentence considered non-germane.
 - b. Associated Laboratories' comment considered non-germane by task group.