



TI-2010-01 03/03/2010

NFRC Technical Interpretation – 2010

<i>*Interpretation Requested:</i>
When revising a report to add a new glass option to an existing matrix and the new glass option has a better center-of-glass U-factor, is it required to report using an additional SHGC / VT 0.0 and 1.0 table for the new options?

<i>Date Requested</i>	<i>Initial Interpretation Date</i>	<i>Final TIPC Approval Date</i>
1/18/2010	2/8/2010	3/3/2010

<i>Pertinent Document:</i>	
NFRC 200 - 2010	
<i>Referenced Sections:</i>	<i>Referenced Pages:</i>
4.5.B	Page 10

<i>**Interpretation:</i>
No. The initial SHGC / VT 0.00 and 1.00 table shall be used for the entire certification cycle and will be modified upon recertification.

<i>**Technical Committee Revisions to Initial Interpretation:</i>