



TIR-2010-01 01/18/2010

NFRC Technical Interpretation – 2010

** To be filled in by the request maker*

*Interpretation Requested:
When revising a report to add glass options where the new glass options have better center-of-glass values, is it required to report using an additional SHGC / VT 0.0 and 1.0 table for the new options?

<i>Date Requested</i>	<i>Initial Interpretation Date</i>	<i>Final TIPC Approval Date</i>
1/18/2010		

<i>Pertinent Document:</i>	
NFRC 200 - 2010	
<i>Referenced Sections:</i>	<i>Referenced Pages:</i>
4.5.B	Page 10

**Interpretation:
Yes. The section above applies to all glazing options within the product grouping; therefore, if the new glass options have a better U-factor, a new table is required. But since the initial options would assume to already be certified, the additional grouping would apply only to the added options within the matrix.

**Technical Committee Revisions to Initial Interpretation: