



NATIONAL FENESTRATION RATING COUNCIL LABEL CERTIFICATE

PROJECT INFORMATION

LABEL CERTIFICATE ID: PJ-ARA-5903

Issuance Date: 10/12/2018

NFRC CERTIFIED PRODUCT RATING INFORMATION:*

This is to be completed by an NFRC Approved Calculation Entity (ACE), based on information provided by the Specifying Authority and calculated in accordance with NFRC procedures.

PROJECT LOCATION:

Address: 3090 South 300 East

City: Washington **State:** UT **Zip Code:** 84780

Contact person: Rick Palmer

Phone: (702) 944-4692 **Facsimile:** **Email:** rpalmer@arcadiainc.com

Project name (optional): Saint George Academy

IDENTIFICATION OF SPECIFYING AUTHORITY:

Company name: Arcadia Inc **ID:** ARA

Address: 4820 Andrews Street

City: North Las Vegas **State:** NV **Zip Code:** 89081

Contact person: RickAPalmer

Phone: 702-944-4692 **Facsimile:** 702-946-5432 **Email:** rpalmer@arcadiainc.com

IDENTIFICATION NAME OF APPROVED CALCULATION ENTITY (ACE) ORGANIZATION:

Company name: WESTLab - California **ID:** WES

Address: 1721 Arroyo Drive

City: Auburn **State:** CA **Zip Code:** 95603

Contact person: Ken Nittler

Phone: 530-885-9891 **Facsimile:** **Email:** ken@westlab.net

IDENTIFICATION NAME OF INSPECTION AGENCY (IA):

Company name: Not Required **ID:**

Address:

City: **State:** **Zip Code:**

Contact person: **Title:**

Phone: **Facsimile:** **Email:**

Number of individual products listed on this label certificate: 1



NATIONAL FENESTRATION RATING COUNCIL LABEL CERTIFICATE

PRODUCT LISTING

FOR CODE COMPLIANCE

LABEL CERTIFICATE ID: PJ-ARA-5903

Issuance Date: 10/12/2016

NFRC CERTIFIED PRODUCT RATING INFORMATION: *

This is to be completed by an NFRC Approved Calculation Entity (ACE), based on information provided by the Specifying Authority and calculated in accordance with NFRC procedures.

PRODUCT LISTING:

CPD ID	Product Name	Framing Ref	Glazing Ref	Spacer Ref	Total Area ft ²	CERTIFIED Performance Rating at NFRC Standard Size			
						U-factor** Btu/ hr·ft ² ·°F	SHGC**	VT**	
Metal - Curtain wall/Storefront/Window Wall						6066.53			
P-ARA-50880	AG-451T Window Wall, 6mm SN88, 1/2" Air, 6mm Clear, 0.942" OA	FA-ARA-23674	GA-GIN-12406	SA-NFC-4609	6066.53	0.40	0.34	0.60	

FRAME, GLAZING and SPACER ASSEMBLIES

FRAMING LISTING:

Framing Ref	Supplier ID	Product Type	Frame Material	Description
FA-ARA-23674	ARA	Glazed Wall System	AT	AG-451T Thermally Broken - Window Wall

GLAZING LISTING:

Glazing Ref	Supplier ID	# Layers	Low-e	Gap Fill	Description
GA-GIN-12406	GIN	2	Y	Air	6mm SN88, 1/2" Air, 6mm Clear, 0.942" OA

SPACER LISTING:

Spacer Ref	Supplier ID	Sealant Config.	Spacer Material	Description
SA-NFC-4609	NFC	N/A	Not Applicable	Generic Aluminum, Path I, Group 1

Note: For NFRC-approved frame, glazing and spacer component performance information see the NFRC Approved Component Library Database <http://omast.nfrc.org/Project/CertificateFind.aspx>

* Certification information provided is for those fenestration systems listed and may not encompass all systems for the project.

** Each individual product certified performance rating is based on NFRC standard size in accordance with NFRC procedures.

FOR CODE COMPLIANCE